




# **AISI** STANDARD

## **Errata to North American Standard for Cold-Formed Steel Framing – Lateral Design 2007 Edition with Supplement No. 1**

October 2009

**Amendment on July 30, 2010**

Endorsed by:



## **Errata to North American Cold-Formed Steel Framing— Lateral Design with Supplement No. 1**

### **Amendment on July 30, 2010**

On page 21, revise Equation D2.1-1 as follows:

$$\delta = \frac{0.052vL^3}{E_s A_c b} + \omega_1 \omega_2 \frac{vL}{\rho G t_{\text{sheathing}}} + \omega_1^{5/4} \omega_2 (\alpha) \left( \frac{v}{2\beta} \right)^2 + \frac{\sum_{j=1}^n \Delta_{ci} X_i}{2b} \quad (\text{Eq. D2.1-1})$$