



# AISI STANDARD

**Errata to Standard for Cold-Formed  
Steel Framing –  
Prescriptive Method for One  
and Two Family Dwellings  
2007 Edition with Supplement 2**

**Amendment on September 10, 2010**

**Amendment on July 29, 2009**

Endorsed by:



## **Errata to Standard for Cold-Formed Steel Framing— Prescriptive Method for One and Two Family Dwellings, 2007 Edition with Supplement 2**

### **Amendment on September 10, 2010**

1. On page 39, Section E7.3, revise the first sentence to:

“An *L-header* shall consist of a cold-formed steel angle with one short leg lapping over the top *track* of the wall and one leg extending down the side of the wall above window or door openings, as shown in Figures E7-5 and E7-6.”

2. On pages 41-42, delete Sections E8.3 and E8.4. In Supplement 2 these sections were moved and became Sections E8.2.3 and E8.2.4 with modifications.

### **Amendment on July 29, 2009**

1. Page 213, section F4.4, 2<sup>nd</sup> Paragraph: change “Figure F3-1” to “Figure F3-2.”

- Corrected sentence:

- Jack rafters shall be connected to a hip member with a minimum 2 inch x 2 inch (51x51 mm) clip angle fastened with No. 10 screws to the hip member in accordance with Figure F3-2 and Table F3-3.